



Certificate of Conformity

The Manufacturer

United Building Chemicals Limited
Peel House, 30 The Downs, Altrincham, Cheshire WA14 2PX
United Kingdom

Declares according to the Construction Products Directive (89/106/EEC)
that the product:

Qmix PLUS

Manufacturing Site
United Building Chemicals Limited
Bradford West Yorkshire BD4 7EA

Conforms to the regulations of EN 934-3:2003 and fulfils the conditions of the CE brand
according to enclosure ZA of EN 934-3:2003

Air Entraining Mortar Plasticiser

	Test	Test Method	Result
1	Homogeneity	Visual	Homogenous
2	Colour	Visual	Red/Brown Liquid
3	Effective Component	EN 480-6	As per Spectra
4	Relative Density	ISO 758	1.01
5	Conventional Dry Material Content	EN 480-8	N/A
6	pH Value	ISO 4316	8.95
7	Total Chlorine	ISO 1158	See Analysis from Butterworth Laboratories
8	Water Soluble Chloride	EN 480-10	< 0.1%
9	Alkali Content	EN 480-12	< 3 % by Mass as Na ₂ O
10	Corrosion Behavior	-	No Performance Determined

For Certification of the factory production control the notified body.



BSI Product Service
Marylands Avenue
Hemel Hempstead
Hertfordshire HP2 4SQ
England
(ID-Nr. 0086)

Certificate of Factory Production Control registration number **0086-CPD-546247** has been issued

Altrincham 01/04/2010

Conformity Declaration No 8/0010R

Colin Mills
for UBC Limited